

# Surge-protective Devices Certified for Canada - Component

**COMPANY**

**Semiware Electronics (Shanghai) Co Ltd**

Building 1  
 No. 9222, Chuannan Fenggong Road  
 Fengxian District  
 Shanghai, 201112 China

E543128

Cat. No.	SPD Type	Volts (V)	AC/DC/ DC PV	AC/DC/ PH	AMPS (A)	AMB		MODE	VPR (Vpk)	MLV (Vpk)	MCOV (V)	Vn (Vdc)	in (kA)	SCCR (kA)	Notes
						Min (°C)	Max (°C)								
<b>Investigated to CSA C22.2 No. 269</b>															
<b>SG2R05B1000-</b>	5	275	AC	1	N/A	-40	125	Ld-Ld	-	1670	275	N/A	3	N/A	1,3
<b>SG2R05B2000-</b>	5	500	AC	1	N/A	-40	125	Ld-Ld	-	2520	500	N/A	3	N/A	1,3
<b>SG2R05B3600-</b>	5	500	AC	1	N/A	-40	125	Ld-Ld	-	3940	500	N/A	3	N/A	1,3
<b>SG2R08B090-</b>	5	24	AC	1	N/A	-40	125	Ld-Ld	-	790	24	N/A	10	N/A	1,3
<b>SG2R08B600-</b>	5	275	AC	1	N/A	-40	125	Ld-Ld	-	1200	275	N/A	10	N/A	1,3
<b>SG3R08B090-</b>	5	24	AC	1	N/A	-40	125	Ld-Ld	-	710	24	N/A	10	N/A	1,3
<b>SG3R08B230-</b>	5	90	AC	1	N/A	-40	125	Ld-Ld	-	460	90	N/A	10	N/A	1,3

**Notes:**

1. Suitable for Factory wiring only.
2. Suitable for Field and Factory wiring.
3. Series External Impedance required, see Electrical Ratings in the Recognition report.
4. Series External Overcurrent Protection required, see Electrical Ratings in the Recognition report.
5. Body of discrete component metal-oxide varistors (MOVs) flammability:
  - a) Min. V-0 or VTM-0.
  - b) Min. V-1 or VTM-1.
  - c) Complies with IEC 60950-1, Edition 2.2, Annex Q/IEC62368-1 Annex G.8.2 needle flame testing requirements.
  - d) Complies with IEC 60065, Edition 7.2, Annex G.1.1 needle flame testing requirements.

6. Complies with Stress Test Qualification per AEC-Q200 Rev D.

7. Suitable for Damp Location use:

a) 85C/85% relative humidity

b) 40C/93% relative humidity

Marking: Company name, model designation and the Recognized Component Mark for Canada,



Last Updated on 2024-08-27

---

并不是所有出现在本数据库中的公司名称和产品都满足了UL 跟踪检验服务的要求。只有带有 UL 标志的产品，才应该被视为经过UL认证，并满足UL 跟踪检验服务的要求。注意查看产品上的标志。

UL 允许在线认证目录中所含材料的复制遵循以下条件：1.指南信息、装配、构造、设计、系统和/或认证（文件）必须在不篡改任何数据（或图纸）的情况下完整且无误导性地呈现。2.“经 UL 允许从在线认证目录转载”声明必须出现在所摘取材料的邻近位置。此外，转载材料必须包含以下格式的版权声明：“©2024 UL LLC.”